



Nicole Larson <larsonn@grafton-ma.gov>

Request for Department Comments - Mod. of a Special Permit (SP 2015-6.1) & Site Plan Approval - Extend Period to Construct Common Drive - 114 Merriam Road - Churchill

Nancy Connors <connorsn@grafton-ma.gov>
To: Nicole Larson <larsonn@grafton-ma.gov>

Thu, Jun 23, 2016 at 3:30 PM

Driveway must be 25 feet from a well and 10 feet from septic tank and 20 feet from leach field.
Nancy.....

Nancy Connors
Office Manager
Town of Grafton
Health Department
30 Providence Road
Grafton, MA 01519
Phone: 508-839-5335 X 1119
Fax: 508-839-8559
connorsn@grafton-ma.gov
www.grafton-ma.gov
Follow Us: [Facebook](#) | [Twitter](#)

RECEIVED

JUN 23 2016

**PLANNING BOARD
GRAFTON, MA**

When responding, please remember the Secretary of State considers e-mail a public record.

Consider the environment before printing this e-mail.

[Quoted text hidden]